


Legend installation-replacement


KLD-22/ST & KLD-30/ST



1


2

KLR-20/ST



1

2



3

4

Accessories for installation (After request)

- A-2130: Accessory for ceiling (1m)
- A-2131: Accessory for ceiling (0,5m)
- A-2132: Accessory for ceiling (0,25m)
- A-2133: Accessory for wall mounting
- A-2136: Accessory for hanging installation (2,5m)
- A-2520/PL/ST: Suspended ceiling base

Battery replacement

1. Disassemble the luminary.
2. Remove the battery connector and carefully remove the battery from its base.
3. Install a new battery of the same type and rating.
4. Assemble the luminary and power the device.

NOTE: LED= Light Emitting Diode

LABELING EXPLANATION:

X: Self contained

1: Maintained (*)

A: Including test device

E: With non-replacable lamp(s) and/or battery

F: Automatic test gear complying with IEC 61347-2-7 denoted EL-T

G: Internally illuminated safety sign

60: 1 hour duration

180: 3 hours duration

480: 8 hours duration

X1AEFG180

(*) **Maintained operation:** The luminary lights its illumination source, when it is powered by the mains power supply or not.

Non Maintained operation: The luminary lights its illumination source, only in mains power supply's failure.

ATTENTION!!!

The light source of this luminary is not replaceable when the light source reaches its end of life the whole luminary shall be replaced.

Technical Characteristics

	KLD-30/ST	KLD-22/ST	KLR-20/ST
OPERATION VOLTAGE		220-240V AC / 50-60Hz	
MAXIMUM POWER CONSUMPTION		3.9W / 4.4VA	
SUPPLY CURRENT		20mA	
U-OUT		70V	
Prated		1.5W	
Irated		130mA	
MAX OPEN CIRCUIT VOLTAGE		39V DC	
EMERGENCY OUTPUT FACTOR (EoFx)		1h: 3.4, 3h: 1.4, 8h: 0.2	
WIRE CROSS SECTION		0.08mm ² - 1.5mm ²	
MINIMUM POWER FACTOR		0.87	
BATTERY (Ni-MH)		3.6V/1.5Ah	
INSULATION BETWEEN SUPPLY & CONTROL TERMINALS		Basic insulation	
INSULATION BETWEEN SUPPLY & BATTERY CIRCUIT		Basic insulation	
BATTERY PROTECTION	Deep discharge and overcharge protection / the control gear will recharge the battery normally after the test of 22.3		
MIN MAX. DISCHARGE VOLTAGE		3 - 4.5V	
MIN MAX. DISCHARGE CURRENT	1h (400-690mA), 3h (190-295mA), 8h (55-95mA)		
MIN MAX. CHARGE CURRENT	20 - 120mA		
TRICKLE CHARGE VOLTAGE/CURRENT	4.4V / 40mA		
MAX CHARGE VOLTAGE	4.9V		
INDICATIONS	LED Charge, Lamp Fault LED, Battery Fault LED / Test Button		
CHARGE TIME	24 hours		
MINIMUM DURATION	1h / 3h / 8h Manually Selected (Default 3h)		
LIGHT SOURCE / OUTPUT MODE	LED / CONSTANT CURRENT		
LIGHT SOURCE LUMINOUS FLUX (MAINS / EMERGENCY)	80lm / 1h: 250lm, 3h: 110lm, 8h: 15lm		
DEGREES OF COVER PROTECTION	IP54		
PRODUCED IN ACCORDANCE WITH	EN 60598-1, EN 60598-2-22, EN 55015, EN 61547, EN 61000-3-2, EN 61000-3-3		
OPERATION TEMPERATURE RANGE	5 to 40 °C		
CONTROL GEAR MAX.TEMPERATURE: tc	58 °C at BR1		
RELATIVE HUMIDITY	Up to 95%		
CONSTRUCTION MATERIAL	PC, Acrylic Plate		PC
EXTERNAL DIMENSION (L x W x H)	310x35x216mm	260x35x180mm	260x35x170mm
WEIGHT	955gr.	740gr.	560gr.
GUARANTEE	3 years (1 year for the battery)		
CONTROL GEAR WITH AUTOMATIC TEST FUNCTION	EL-T		

LED Characteristics

	KLD-30/ST	KLD-22/ST	KLR-20/ST
MANUFACTURER	Olympia Electronics S.A.		
MODEL NUMBER	2711195		
VOLTAGE RANGE	11.2-13.2V DC		
NOMINAL POWER	0.72		
CONNECTIONS	Built-in main board		
TEMPERATURE	45 °C max. across the board		

Warranty

Olympia Electronics guarantees the quality, condition and operation of the goods. The period of warranty is specified in the official catalogue of Olympia Electronics and also in the technical leaflet, which accompanies each product. This warranty ceases to exist if the buyer does not follow the technical instructions included in official documents given by Olympia Electronics or if the buyer modifies the goods provided or has any repairs or re-setting done by a third party, unless Olympia Electronics has fully agreed to them in writing. Products that have been damaged can be returned to the premises of our company for repair or replacement, as long as the warranty period is valid.

Olympia Electronics reserves the right to repair or to replace the returned goods and to or not charge the buyer depending on the reason of deflection. Olympia Electronics reserves the right to charge or not the buyer the transportation cost.



72nd km. O.N.R. Thessaloniki-Katerini
P.C. 60300 P.O. Box 06 Eginio Pierias Greece
www.olympia-electronics.com
info@olympia-electronics.gr



KLD-30/ST, KLD-22/ST & KLR-20/ST

SELF TESTING MAINTAINED
EMERGENCY ILLUMINATION SIGNS



Thank you for your trust in our products
Olympia Electronics - European manufacturer

Package contents


1	Luminaire
1	Wall mounting accessories
1	Ceiling mounting accessories
1	Manual
1	Set of Pictograms

General

These luminaires are used indoors (ta 40°C) where emergency light is needed. Each luminaire must be permanently connected to mains power supply. In normal operation the led strip lights and the battery is charging. In case of a mains power supply failure the luminaire will light the led strip automatically in emergency mode (powered by its battery). When the mains power supply is restored the device turns to normal operation.

Manual test for emergency operation and light source.

The manual test can be conducted only if the mains power supply and the battery is connected:



During the Test the lamp fault LED blinks.

Manual Autonomy Test

A duration test can be conducted if the TEST button is pressed from 5 to 10 seconds. The luminaire enters emergency mode, the charge LED is turned OFF and the Battery Fault led starts to blink. The test is conducted until the battery is depleted. If at the end of the test the autonomy is low then the Battery Fault LED will be ON. If the result of the test is good then the luminaire enters charging mode and the Charge led starts to blink until the batteries are fully charged.

Automatic Operational Test

This test includes all the operations that provide the manual test and is conducted automatically every 15 days. In order to be performed, the mains power supply and the battery should be connected.

Automatic Autonomy Test

The Automatic Autonomy Test is conducted every 6 months and measures the device's back up operation and emergency duration. This test includes all functions of the Manual Autonomy Test.

Resetting errors

Push the test button for more than 10 seconds, to delete all the LED indicated errors. Then the device enters regular operation mode.

ATTENTION!!!


- Operations for installation, maintenance or testing must be done by authorized personnel only.
- The device must be connected to the mains power supply through a fuse that is dependent on the total line's power load.
- In case of battery replacement, this must be replaced by part of the same type, by the manufacturer or by a competent person.
- In case of inactive use for a period greater than 2 months, disconnect the battery by pulling out the battery's connector.
- The control gear is not proof against supply voltage polarity reversal.
- It is not allowed to discard batteries into common trash bins, they must be discarded only in battery recycling points. Do not incinerate.**

Connectors


- CN10: Power connector
- CN11: Communication Port
- CN6 & CN7: Battery connector
- CN9: Module Port
- CN5: Non user connector
- CN7: Recess LED Port

Installation methods


Luminaire disassembly




Wall mounting



Hanging installation




Ceiling mounting




After the desired installation follow the steps below

Insert the power cable




Power Connection





N for neutral, L for live wire

1



Maintained operation Non-maintained operation



1h

3h
(default position)

8h

Autonomy duration selection

The user can select one of the 3 available minimum autonomy durations 1 hour, 3 hours and 8 hours. The selection must be done while the luminaire is disconnected from AC and battery supplies. The selection is achieved through Switches 2 & 3 of DS1. Switch 1 is not used.

Changing the operating mode


The control of maintained or non maintained operation of the luminaire is achieved through Switch 4 of DS1. For maintained operation, switch number 4 must be in ON position. For non-maintained operation, switch number 4 must be in OFF position.

Technical label installation

Two additional labels are included in the package. one for 1 hour duration (60) and one for 8 hour duration (480). Depending on the selected duration, the installer must cover the default 3 hour (180) printing with one label that has the required duration. Please take notice of the orientation of the label.


2

Battery Connection



3

Luminaire assembly



4

Indications LED Status

CHARGE (green)	LAMP FAULT (red)	BATT. FAULT (yellow)	Description
⬢	⊗	⊗	Charging
●	∅	∅	Fully charged
○	∅	∅	Battery fault or emergency mode
∅	⊗	∅	Operational test
∅	●	∅	Light source fault
∅	∅	⊗	Autonomy test
∅	∅	●	Duration fault

Note:

●	Permanently ON
⊗	Blink
○	Off
∅	Indifferent